

AC GENERATOR ASSEMBLY FORM

JOB# 2307011 / PO# 57612

DATE: 7/24/2023

ASSEMBLED BY: RICARDO YANEZ

NAME PLATE DATA			
SERIAL #:	21660-23	VOLTAGE:	346/600
MODEL #:	AA27673013	KW:	1204
MAKE:	KATO	AMPS:	1655
TYPE:		RPM:	1200
		HZ:	60
		PF:	
		SF:	

BEFORE ASSEMBLY MECHANICAL

Stator Megger	1000	M Ω	Stator Surge	2230	volts	
Stator Hipot	154	M Ω		2420	volts	
				15.750	micro amps	
Stator Resistance	1- 7.22	m Ω	2- 7.29	m Ω	3- 7.21	m Ω
Rotor Megger	1000+	M Ω	Rotor Drop Test in File	√		
Rotor Hipot	734	M Ω		2210	volts	
				3.101	micro amps	
Exc. Stator Hipot	46486	M Ω		1720	volts	
				0.037	micro amps	
Exc. Stator Polarity Test	GOOD					
Exc. Rotor Hipot	1714	M Ω		1520	volts	
				6.887	micro amps	
Exc. Rotor Resistance	1- -	m Ω	2- -	m Ω	3- -	m Ω
Exc. Rotor Surge	1240	volts	PMG Electrical in File	√		

RTD's	1	N/A	ohms	2	-	ohms	3	-	ohms
	4	-	ohms	5	-	ohms	6	-	ohms

HEATERS	QTY.	2	Rating	120V-500W
---------	------	---	--------	-----------

DC ROTOR DROP TEST AND POLARITY			INPUT VOLTAGE:	120	
1	23.0	2	23.4	3	23.4
4	25.0	5	23.1	6	23.1
7	-	8	-	9	-

ASSEMBLY MECHANICAL

RUN-OUT	0.001	ENDPLAY	0.027
	D.E.		O.D.E.
Bearing Journal	5.1190		5.1191
Bearing Housing	11.0243		11.0241
Bearing size/MFG.	6326 / SKF		6326 / SKF
Grease Type	278 POLYUREA		278 POLYUREA
Shaft Size	5"	Key Way Size	1.235

GENERAL VISUAL INSPECTION			
Rotor Cleaned <input checked="" type="checkbox"/>	Stator Clean <input checked="" type="checkbox"/>	Leads Good Cond. <input checked="" type="checkbox"/>	Covers <input checked="" type="checkbox"/>
Rotor Painted <input checked="" type="checkbox"/>	Fits Clean <input checked="" type="checkbox"/>	Lugs Installed <input checked="" type="checkbox"/>	J-Box <input checked="" type="checkbox"/>
Rotor Balanced <input checked="" type="checkbox"/>	Stator Tapped <input checked="" type="checkbox"/>	Terminal Block <input checked="" type="checkbox"/>	Fan <input checked="" type="checkbox"/>
Balance sheet in file <input checked="" type="checkbox"/>	Feet Clean <input checked="" type="checkbox"/>	Grease Fits Clean <input checked="" type="checkbox"/>	Fan Cover <input checked="" type="checkbox"/>
Stator Varnish Dip <input checked="" type="checkbox"/>	Winding Painted <input checked="" type="checkbox"/>	Bolts Clean <input checked="" type="checkbox"/>	Final Paint <input type="checkbox"/>
Rotor Varnish Dip <input checked="" type="checkbox"/>	EXC Stator Dip <input checked="" type="checkbox"/>	EXC. Rotor Dip <input checked="" type="checkbox"/>	PMG Dip <input type="checkbox"/>

BEFORE CONNECTING FOR TEST RUN

Stator Megger 1000+ M Ω

TEST RUN - SINGLE BEARING GENERATOR - STATIC ELECTRICAL TESTING ONLY					
# LEADS	WYE	DELTA	EITHER	BUS BAR	
48	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Gen. Output Voltage 605.1 VAC

Exc. Field Resistance 14.0 Ohms

Excitation Input Voltage 20.35 VDC

No Load RPM's N/A

VIBRATION READING			
D.E.		O.D.E	
H	<u>0.09</u>	H	<u>0.09</u>
V	<u>0.08</u>	V	<u>0.09</u>
A	<u>0.08</u>	A	<u>0.08</u>

BEARING TEMPERATURE READINGS			
Bearing temperature will be taken in intervals of 5 minutes and in degree Celcius			
D.E.		O.D.E	
1	<u>33.5</u>	7	<u>41.5</u>
2	<u>34.8</u>	8	<u>43.1</u>
3	<u>36.4</u>	9	<u>44.2</u>
4	<u>37.8</u>	10	<u>45.8</u>
5	<u>39.1</u>	11	<u>44.8</u>
6	<u>40.1</u>	12	<u>45.1</u>
1	<u>31.8</u>	7	<u>40.4</u>
2	<u>33.9</u>	8	<u>41.9</u>
3	<u>36.8</u>	9	<u>42.1</u>
4	<u>37.5</u>	10	<u>42.9</u>
5	<u>38.5</u>	11	<u>43.1</u>
6	<u>39.1</u>	12	<u>43.5</u>

Assembled by: RICARDO YANEZ

Date: 7/24/2023

Tested by: RICARDO YANEZ

Date: 7/24/2023

Supervisor JOEL RIOS

Date: 7/24/2023